

**STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT**



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 13-51-06941 Name of Facility: Sunset Elementary Address: 5120 SW 72nd Street City, Zip: South Miami 33143 Type: Public Schools Owner: M-DCSB Food and Nutrition Person In Charge: Sunset Elementary PIC Email: _____ Phone: 3056618527	Correct By: Next Inspection Re-Inspection Date: None
--	---

Inspection Information

Purpose: Routine Inspection Date: 5/16/2023	Begin Time: 10:04 AM End Time: 11:18 AM
--	--

Additional Information

FEMALES 582 MALES 600	CENSUS 1182
--------------------------------------	-------------------

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION IN 1. School Site IN 2. Playground, Equip & Athletic Fields* NA 3. Athletic & Playground Equipment BUILDING CONST/MAINT. NA 4. Construction OUT 5. Maintenance & Repair OUT 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation IN 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation	IN 11. Group Toilet Rooms IN 12. Toilet Facilities IN 13. Handwashing Facilities IN 14. Soap Dispensers NA 15. Shower Facilities NA 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source IN 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal IN 20. Solid Waste PEST CONTROL	IN 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION NA 23. Sanitizers NA 24. Changing Station & Mats NA 25. Hand Sink NA 26. Garbage Can ANIMAL HEALTH & SAFETY NA 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES NA 28. Maintenance/Complaint NA 29. Other
--	--	---

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

General Comments

Satisfactory Email Address(es): anaalvarez-arimon@dadeschools.net
--

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #5. Maintenance & Repair

Observed dim lightbulbs in classroom 1 (39fc). Replace lightbulbs

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #6. Lighting Standards

Observed lightbulbs out in classroom E (25fc). Not enough adequate lightning. Replace lightbulbs.

Observed dim lighbulb in bathroom of classroom 815 (14fc) . Replace lightbulb.

CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.

Inspection Conducted By: Javon Johnakin (27326)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name:
Date: 5/16/2023

Inspector Signature:

Client Signature: